

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.  
Por favor hable con alguien que lo pueda traducir

---

### Lakeside School Has Levels of Arsenic Above Drinking Water Standards

---

Our water system failed a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results collected on January 17, 2020 show that our system exceeds the standard, or maximum contaminant level (MCL), for arsenic. The standard for arsenic is 10 ug/L (micrograms per liter). The level of arsenic in January was 16 ug/L.

#### What should I do?

- **You do not need to use an alternative (e.g. , bottled) water supply.** However, if you have specific health concerns, consult your doctor.
- This is not an emergency. If it had been, you would have been notified immediately. However, *some people who drink water containing arsenic in excess of the MCL over many years may experience skin damage or circulatory system problems, and may have an increased risk of getting cancer.*
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

#### What happened? What was done?

We are currently working with the [City of Bakersfield](#) and the [State Water Resources Control Board](#), so we may possibly consolidate with the city for drinking water. We anticipate resolving the problem soon.

For more information, please contact Horacio Cruz at 661-831-3503 or at the following mailing address: [14535 Old River Road, Bakersfield CA 93311](#).

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

#### Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by Lakeside School.

Date distributed: 02/24/2020.